




**FS Expert**  
**(TÜV Rheinland**  
**#144/09, SIS/FSM)**

Work in Functional Safety (Yokogawa) since 1992.  
Various positions in Project management & Project Engineering.

With Yokogawa Malaysia from 2004 - 2022

Certified in 2009:	TÜV Rheinland FS Expert (SIS/FSM)
2011	TÜV Rheinland FS Eng Trainer
2017	TÜV Rheinland FS Technician Trainer

- HAZOP / SIL Classification Facilitator
- FSM Manager
- FS Auditor
- Project Safety assessments and (Site) validation Assessor
- Functional Safety trainings
- Member of MT61508-1/2, MT61508-3 & MT61511
- **Proof Test Consultancy**





# 5TH EUROPEAN CONFERENCE 2025 ON PLANT & PROCESS SAFETY

16 & 17 DECEMBER 2025

## Proof Testing SIL Loops - Practical Experiences

**Arjen de Koning**

FS Expert (TÜV Rheinland #144/09, SIS)

Yokogawa Europe B.V., The Netherlands

December, 2025

# Agenda

1. Proof test in IEC61511
2. Proof Test Project
  - I. Preparation - Collection
  - II. Creation of Proof Test Dossiers
  - III. Execution of Proof Test
  - IV. Analysis of Proof Test Results
3. Results of some other Proof Test execution
4. Take away

## 16.3.1 Proof testing

**16.3.1.1** Periodic proof tests shall be conducted using a written procedure to **reveal undetected faults** that prevent the SIS from operating in accordance with the SRS

**16.3.1.2** The entire SIS shall be tested including the sensor(s), the logic solver and the final element(s) (e.g., shutdown valves and motors).


NOTE Testing of the SIS can be performed either end-to-end or in segments (see 11.8.1).

**16.3.1.3** The schedule for the proof tests shall be according to the SRS.

The frequency of proof tests for a SIF shall be determined through

PFDavg or PFH calculation in accordance with 11.9 for the SIS as installed in the operating environment.

NOTE **Different parts of the SIS can require different test intervals**, for example, the logic solver can require a different test interval than the sensors or final elements



## 16.3.1 Proof testing

16.3.1.4 Any deficiencies found during the proof testing shall be repaired in a safe and timely manner. A proof test **shall be repeated** after the repair is completed.

16.3.1.5 At some periodic interval (determined by the user), **the frequency of testing shall be re-evaluated** based on various factors including historical test data, plant experience and hardware degradation.

16.3.1.6 Any change to the application program requires full validation and a proof test of any SIF impacted by the change. Exceptions to this are allowed if appropriate review and partial testing of changes are carried out to ensure the changes were designed per the updated safety requirements and correctly implemented.

16.3.1.7 Suitable management procedures shall be applied to review deferrals and prevent significant delay to proof testing.

# What is Proof Test

A proof test means a complete test of the SIF.

The purpose of the proof test is to reveal all undetected failures that are present in the SIF

After the proof test the elements in the SIF should be in their initial state

SIF must be tested completely

Also allowed to split it in sensor, LS and final elements and test separately

Also allowed to use (false) trip as a proof test, if recorded that actions were successful.

**Proof test does not mean only a functionality check confirming the (expected) function of the complete SIF or SIF input only!**

# BUT.....

**What about:**

## 16.3.2 Inspection

Each SIS shall be periodically visually inspected to ensure there are no unauthorized modifications and no observable deterioration (e.g., missing bolts or instrument covers, rusted brackets, open wires, broken conduits, broken heat tracing, and missing insulation).

NOTE These problems could indicate an increase in the frequency of faults.

# And ..... Documentation (Part of Proof Test Dossier)

## 16.3.3 Documentation of proof tests and inspection

The user shall maintain records that certify that proof tests and inspections were completed as required. These records shall include the following information as a minimum:

- a) description of the tests and inspections performed including identification of the test procedure used;
- b) dates of the tests and inspections;
- c) name of the person(s) who performed the tests and inspections;
- d) serial number or other unique identifier of the system tested (e.g., loop number, tag number, equipment number, and SIF number);
- e) results of the tests and inspection including the “as-found” condition, all faults found (including the failure mode) and the "as-left" condition.

# Let's do Proof test!

## Easier said than done

Client:

- Original HAZOP report is not available.
- SIL classification was done for this existing site based on the crosses (X) on the C&E.



After SIL Classification;

Proof testing is a KPI for the Facility Functional Safety compliance

But nothing available.

Start from Scratch




## 2. Proof Test Preparation: Project Scope


### Site: Ethylene / Polyethylene Plant

Built in mid 90's

Ethylene  $C_2H_4$  Plant –  
157 SIF's      **96 +16 Selected during Site**      SIL 0 - 3



Polyethylene  $(C_2H_4)_n$  Plant –  
52 SIF's      **48 selected**      SIL 1 - 3




**Note: > 40% of the SIF's are SIL 3 rated**

## 2. Proof Test Preparation: Project Team


### Project team: 1 Lead with 5 safety engineers

- 4 months preparing the 144 SIF proof test dossier.
- 4 weeks at site – Actual Proof Test Execution
- What is needed to Create this Proof test procedure & Dossier?



## 2. Proof test Preparation: Proof Test Procedure & Dossier

- **IEC-61511 Standard**
- **HSE UK crr428/2002 (OG54)**
- Safety Manuals of each device in the SIF
  - Proof test procedure/methodology devices
  - Proof Test coverage of each device
- Application logic and settings/Parameters
- P&ID
- Datasheets



## 2. Proof test Preparation: Proof Test Procedure

### What is needed to Creation of Proof test procedure

- IEC-61508/61511 Standards
- HSE UK crr02428
- **Safety Manuals of all devices in the SIF**
  - **Proof test procedure/methodology of the devices**
  - **Proof Test coverage of these devices**
- Application logic and settings/Parameters
- P&ID
- Datasheets

Technical Information	Functional Safety Manual	DPharp <b>EJX</b> <sup>™</sup> DPharp <b>EJA</b> <sup>™</sup>
TI 01C25A05-01EN		
<b>Contents</b>		
Certificate.....		1
Revision List.....		2
< English >		
1.	<b>Safety Instrumented Systems Installation .....</b>	<b>5</b>
1.1	Scope and Purpose .....	5
1.2	Using the transmitter for an SIS Application .....	5
1.2.1	Safety Accuracy .....	5
1.2.2	Diagnostic Response Time .....	5
1.2.3	Setup .....	5
1.2.4	Required Parameter Settings .....	6
1.2.5	Proof Testing .....	6
1.2.6	Repair and Replacement .....	7
1.2.7	Startup Time .....	7
1.2.8	Firmware Update.....	7
1.2.9	Reliability Data .....	7
1.2.10	Lifetime Limits .....	7
1.2.11	Environmental Limits.....	7
1.2.12	Application Limits .....	7
1.3	Definitions and abbreviations .....	8
1.3.1	Definitions.....	8
1.3.2	Abbreviations .....	8
2.	<b>Functional Safety Data Sheet .....</b>	<b>9</b>

## 2. Proof test Preparation: Proof Test Methodology & Coverage

### Transmitters

Testing method	Tools required	Expected outcome	Remarks
<b>Functional test:</b> 1. Follow all Management of Change procedures to bypass logic solvers if necessary. 2. Execute HART/BRAIN command to send value to high alarm (21.6 mA) and verify that current has reached this level. 3. Execute HART/BRAIN command to send value to low alarm (3.6 mA) and verify that current has reached this level. 4. Restore logic solvers operation and verify.	• Handheld terminal	Proof Test Coverage =52%	The output needs to be monitored to assure that the transmitter communicates the correct signal.
Perform three point calibration along with the functional test listed above.	• Handheld terminal • Calibrated pressure source	Proof Test Coverage =99%	

PTC test sequence A <sup>5)</sup>	88 %	
PTC test sequence B <sup>6)</sup>	34 %	38 %
PTC test sequence C <sup>7)</sup>	-	88 %

- 1) This value takes into account failure types relevant to the function of the electronic components according to Siemens SN29500.
- 2) During this time, all diagnostic functions are tested at least once.
- 3) Time between error detection and error response.
- 4) Step response time as per DIN EN 61298-2.
- 5) Proof test coverage when the level is approached, or when the sensor is removed and the tines are immersed in a medium of similar density and viscosity.
- 6) Proof test coverage when simulation is performed on the Nivotester by activating the test button.
- 7) Proof test coverage when checking the switch point under reference operating conditions.

### Valve / Actuator Assembly

#### Proof Test Coverage (PTC) / Diagnostic Coverage (DC)

Considering the application of the above described Test procedure, the "Test Coverage", in case of automatic procedure, can be considered > 99% (it will be lower in case of imperfection/incompleteness of the test procedure and/or use of not calibrated/adequate equipment).

In case of manual procedure the "Test Coverage" shall take into account also the test imperfection and the reliability/competence of the operator.

#### 6.2 Full Stroke Test

The "Full Stroke Test" ("On-line") must be performed to satisfy the PFDAVG (average probability of failure on demand) value.

The full test frequencies will be defined from the final integrator, in relation to the defined SIL level to achieve.

##### Procedure:

- Operate the Actuator/Valve assembly for an open/close complete cycle, with complete opening - closing of the valve.
- Verify the Correct performing of open – close manoeuvre (e.g. check locally, or automatically, via Logic solver, the correct movement of the actuator/valve).

Considering the application of the above described Full Stroke Test procedure, the "Test Coverage" can be considered 99%.

## 2. Proof test Preparation: Proof Test Methodology & Coverage

### Valve (PTC?)

#### 6.2 Full Stroke + Leak Test

The "Full Stroke + Leak Test" ("On line") must be performed to satisfy the  $PFD_{AVG}$  (average probability of failure on demand) value.

The test frequencies shall be defined from the final integrator in relation to the defined SIL grade to achieve.

##### Procedure for Full Stroke Test

- Operate the Actuator/Valve assembly for No. 2 open/close complete cycles with complete closing of the valve.
- Verify the correct performing of open – close manoeuvre (e.g. check locally, or automatically via Logic solver, the correct movement of the actuator/valve).

The achievement of the safe position (open or closed) shall be confirmed with the control of:

- The OPEN/CLOSED indications on actuator and the relative feedback to the logic solver, if existing. (see the specific actuator operating manual for details)
- The mechanical position indicator on actuator and/or valves, if existing; (see the specific actuator operating manual and/or the valve assembly drawing for details)

##### Procedure for Leak Test On Line

The Valve assembly shall be operated in order to reach the closed position.

(The closed position shall be verified and confirmed as described above).

Then, the pressure value shall be checked using the manometers or automatic system installed on line, upstream of the valve: the absence of the seat leakage shall be confirmed by any pressure loss.

With the available plant facilities, the seat leakage can also be measured downstream of the valve and read by the logic solver.

**No Proof Test Coverage  
What to choose?**

90% ? or.....

### SOV

Mode of Operation		Low Demand
Proof Test Coverage	PTC	92 %
Partial Stroke Test Coverage	PSTC	70 %

### SOV (PTC?)

#### 3.2.1 Suggested Proof Test

The suggested proof test consists of a full stroke of the final element actuator and valve. It is assumed that the BXS valve is able to perform the safety function properly if the final element reaches the safety state within the specified safety time.

##### Step Action


- 1 Bypass the safety function and take appropriate action to avoid a false trip
- 2 De-energise the BXS Valve to force the actuator and valve to the fail-safe state and confirm that the safe state was achieved and within the correct time.
- 3 Return the BXS valve to the energised state and inspect the final element for any leaks, visible damage or contamination and confirm that the normal operating state was achieved.
- 4 Remove the bypass otherwise restore normal operation.

**Proof Test is not a Diagnostic Test ...**

**PTC ≠ DC**

# What is needed to Creation of Proof test procedure

- **Functional Logic Diagrams and/or C&E and/or safety narratives and (any) settings/Parameters**
- P&ID
- Datasheets




## 2. Proof test Preparation: Proof Test Procedure

### What is needed to Creation of Proof test procedure

- IEC-61508/61511 Standards
- HSE UK crr02428
- Safety Manuals of each device in
  - Proof test procedure/methodol
  - Proof Test coverage of each de
- Application logic and settings/Para

- **P&ID's**
- Datasheets



## 2. Proof test Preparation: Proof Test Procedure

### What is needed to Creation of Proof test procedure

- IEC-61508/61511 Standards
- HSE UK crr02428
- Safety Manuals of each device in the SIF
  - Proof test procedure/methodology devices
  - Proof Test coverage of each device
- Application logic and settings/Parameters
- P&ID
- **Datasheets:**  
**Sensors, Final Elements**

GENERAL	
1	Tag Number
2	Service
3	P&ID No.
4	Area Classification
5	Ambient Temperature
6	Minimum Seat Leakage Class
7	Minimum Seat Leakage Rate
8	Failure Position
9	Air Supply Pressure
10	
LINE	
11	Line No.
12	Line Size and Sch.
13	Material
14	Insulation
15	
PROCESS DATA	
16	Fluid
17	Temperature
18	Inlet Pressure @ Max Flow
19	Max Diff. Pressure for Actuator Size
20	Design Pressure
21	Design Temperature
22	
BODY	
23	MFR
24	Type
25	Size
26	End Connects
27	Flange Face Finish
28	Bonnet Type
29	Bolting Material
30	Packing
31	
TRIM	
32	Type
33	Rated Cv
34	Guiding
35	Seat Tight
36	Flow Direction
37	
ACTUATOR	
38	Manufacturer
39	Actuator Type
40	Mounting Position
41	Operating Signal
42	
SOLENOID VALVE	
43	Tag Number
44	MFR
45	Type
46	Electrical Connection
47	Tag No Open
48	Manufacturer
49	Type
50	Certification
51	
SWITCHES	
52	Manufacturer
53	Vendor
PURCHASE	
54	Model
55	Purchase Order Number

Service : * See Below			
ate	Blind		
OL, 2 Wires			
Size	Color		
ace	Yoke		
PIPE Mounting Bracket With Bolt & Nut			
Explosion Proof : Ex-ia IIB T3			
stem	Other		
ma	0-10mA		
D	Other		
ated range or better			
um	Absolute		
vice	Compound		
ix	Bourdon		
copper			
ange	MFR. STD		
1.3 Times of F.S			
low	Max		
NPT	Other		
NPT	Back		
NPT	Other		
se	Diaph		
illary:	Length		
2-Way Valve, Conn : 1/2" NPT(F)			
ss.	Temp.	Service	Remarks
(G)	(°C)		
Max	Nor / Max		
5	4 / 85	NG TO PK-4001	Note. 1
5	4 / 85	NG TO PK-4001	Note. 1
5	4 / 85	NG TO PK-4001	Note. 1

Notes:

1. Supply of Automated Valve shall be in accordance with the following specifications: UG-BUL-00-FLU1-100025 - Specification for Valves, UG-BUL-00-FLU1-100035 - Specification for Piping Material and Design, UG-BUL-00-FLU1-100017 - Specification for Painting, UG-BUL-00-FLU1-570017 - Specification for On/Off Valve Control Panels and Actuators.
2. Fugitive Emissions - manufacturer standard in compliance as per ISO 15848-1 2006 - Industrial valves.
3. PMI test as per UG-BUL-00-FLU1-100025 - Specification for Valves section 7.8.
4. All valve used as an ESDV, BDV or SDV shall be certified fire-safe and comply to standard ISO 10497 and hold a valid Fire test certification.
5. Painting shall comply with section 10 of API SPEC 6D. See document no. UG-BUL-00-FLU1-100017.
6. Inspection and test requirement as per UG-BUL-00-FLU1-100025 section 11, acceptance criteria in section 12 and documentation on section 13.
7. All tubing shall be 3/8" 316 SST seamless with 316SSST double ferrule tube fittings. See section 11.4 of UG-BUL-00-FLU1-570001.
8. Solenoid vent to be provided with sand guard and bug screen.

10. Valve shall have partial stroke testing capability achieve by means of position control. Positioner equipped with position feedback with partial stroke test capability and test feedback functions is required. See section 7.1 of UG-BUL-00-FLU1-570017.

11. Perilous Classification is Duty / Fluid code: HC/Severe

## 2. II. Creation of Proof Test Dossier

### What is needed for the Proof test Procedure?

- First check (**Inspection**): Basic Preparation, Visual Inspection and Spare parts
- Combine all SIF devices proof test procedures in 1 comprehensive SIF proof test procedure

Also include all possible application functions to reveal **undetected faults**, e.g.:

- Out of range behavior
- MOS/Interlock behavior
- di/dt behavior / Rate of rise behavior
- Voting (1oo2 / 2oo2/ 2oo3/ 2oo4 /1oo3)
- Line fault behavior
- HH/LL trip(s)
- Hysteresis behavior
- Input Discrepancy Behavior
- Hart settings for Smart equipment
- Cybersecurity (Smart Devices: Write protect)
- Valve position (and/or other) feedback requirements. Leak test requirements

### Result:

Simple SIF 1oo1 (I/O)	app. 20-25 steps	Actual test takes app. 1 -1.5 hour
Complex SIF 2oo3 (I)/1oo2 (O)	app. 40-60 steps	Actual test takes app. 3 - 4 hours

## 2. II. Pressure Transmitter Low Test (1001) ; Yokogawa EJX Pressure transmitter.

Step	Pressure Transmitter Test (1001) Sequence	OK
1.	JHA completed. Valid PERMIT TO WORK available.	
2.	Inform Technician(s) in the field which pressure transmitter and valves are to be tested.	
3.	Verify Mechanical Integrity pressure transmitter & Valves. <u>Refer to calibration test report results.</u>	
4.	<del>Follow end-user bypass procedures to bypass the RS logic solvers.</del> Pressure transmitter ready to be proof tested with handheld terminal	
5.	Parameter settings verification: Burnout direction switch: Output to 21.6 mA upon detection of internal Failure. Write protection Switch: Enabled	
6.	Execute HART/BRAIN command to send value to high alarm (21.5 mA /109.4%) and verify that current has reached this level. <ul style="list-style-type: none"> <li>Verify transmitter Fault (High) alarm at 21mA/106.3% in SIS and DCS</li> </ul>	
7.	Execute HART/BRAIN command to send value to low alarm (3.6 mA/-2.5%) and verify that current has reached this level. <ul style="list-style-type: none"> <li>Verify transmitter Fault (Low) alarm at 3.8mA/-1.25% in SIS and DCS</li> </ul>	
8.	Restore RS logic solvers operation and verify.  <i>Note: Point 5-8 provides a transmitter proof test coverage of 52%.</i>	
9.	Remove the bypass and confirm pressure transmitter is operational.	
10.	<del>Re-confirm with the Technician(s) in the field which pressure transmitter and which valves are to be tested.</del>	
11.	Isolate the Impulse Lines, Slowly open the Vent Valve to allow the pressure to fall <b>SLOWLY</b> .	
12.	The <b>Low (Low)</b> process alarm (1 <sup>st</sup> point calibration) will be initiated. <ul style="list-style-type: none"> <li>Record the Field value reading (via Handheld terminal)</li> <li>Record the SIS reading.</li> <li>Verify Annunciator alarm on SIS and DCS (&amp; SOE recorder)</li> </ul>	
13.	Continue to allow pressure to fall until the <b>Low Low (Low)</b> process trip (2 <sup>nd</sup> point calibration) is initiated. <ul style="list-style-type: none"> <li>Record the Field value reading (via Handheld terminal)</li> <li>Record the SIS reading.</li> <li>Record the time of initiation.</li> <li>Verify the Trip alarm on SIS and DCS (&amp; SOE recorder)</li> </ul>	

Step	Pressure Transmitter Test (1001) Sequence	OK
14.	Check that the valve(s) (XV, FV and/or PV) have tripped closed in accordance with the Interlock Diagrams. <ul style="list-style-type: none"> <li>Verify the for XV's the limit switch ZSC is activated.</li> <li>Record the time of valve closure</li> </ul>	
15.	Check and record the zero reading of the transmitter at process pressure (3 <sup>rd</sup> point calibration). If the error is more than 2% (EJX Safety Accuracy) then the test has Failed. <i>Note: Point 6-8, 12, 13 and 15 provides a transmitter proof test coverage of 99%.</i>	
16.	Recommission the pressure transmitter.	
17.	When process conditions are stable reset the trip via the SD reset button	
18.	Check that the annunciator & Trip alarms returned to a healthy condition.	
19.	If any part of the system failed to operate correctly or if the reading did not correspond with the required (on the P&ID) annunciator or trip <u>setting</u> then the test has failed. Check each item of the loop. Repair and re-test where necessary.  If extensive repair has to be carried <u>out</u> then a <u>punchlist</u> will be created and the end-user will be informed.	
20.	Check that process conditions and <u>annunciation(s)</u> have returned to normal. Ensure valves are return to normal.	
21.	Inform Technician(s) in the field that testing is completed	
22.	<b>End of Pressure Transmitter Test (1001) Sequence</b>	

## 2. II. Creation of Proof Test Dossier

### Appendices for the used Documents (Mark up to show proof test results)

- SIL report Particular SIF
- P&ID
- Interlock Logic Diagram (FLD's)
- Loop drawings
- Termination Diagrams
- Application Logic printout
- Punch item record
- SIL Calculation
- Proof Test Check sheet (Inspection)
- Data sheets of all Equipment
- Safety Manuals of all equipment

Appendix I  
Punch List Proof Test  
Number of pages that follow : 1

Appendix II  
Proof Test Check Sheet F-101 SIF PSLLL-101-7  
Number of pages that follow: 1

Appendix III  
Reliability Calculation PSLLL-101-7 SIF 30  
Number of pages that follow : 3

Appendix IV  
IPF Report F-101 Safety Function Classification Sheet  
Number of pages that follow : 1

Appendix V  
P&ID Cracking Heater Absorbed Duty F-101  
Number of pages that follow : 2

Appendix VI  
Interlock Logic Diagram  
Number of pages that follow : 1

Appendix VII  
Loop Drawings F-101 SIF 30  
Number of pages that follow : 10

Appendix VIII  
Termination Drawings  
Number of pages that follow : 3

Appendix IX  
Application Logic (Furnace)  
Number of pages that follow : 4

2. II. Creation of Proof Test Dossier: Appendix Proof test Check Sheet

TOP SECT

Plant ID

SIF Function

Test Date and Time

Tested by

Witnessed by

Test Procedure

Plant ID : Unit : HPPS

SIF Function : To prevent High pressure transfer to shore

Test Date and Time : Tag Number : PIT-0520A/B/C - CG-810

Tested by : Authorized by : Reason if NOT passed:

Witnessed by : Overall Test result: PASS ☐ FAIL ☐

Test Procedure : SIF Proof Test Procedure Calibration: PASS ☐ FAIL ☐ N.A. ☐ Date: \_\_\_\_\_

SIF architecture drawing (or reference to loop/drawings, logic drawings etc.):

SIF SE: PIT-0520A/B/C  
SIF FE: CG-810  
1. P&ID: TBA  
2. Loopdrawing SE: TBA  
3. Loopdrawing FE: TBA  
4. Technical Datasheets Pressure Transmitter Rev 0  
5. SHI HN2118 FSRU HPPS Project Logic Wiring Drawings: 10.141.020, 100LG Rev 2  
6. SHI HN2118 FSRU HPPS Project Termination Drawings: 10.141.020, 100TW Rev 2  
7. Instruction for Operation and Maintenance: 10.141.020, IOM Rev 1.0

SIF hardware description (make, type, voltage, channel, position etc.):

Sensor Element						
Sensor	Make / Device	Serial Number	Type	Range	Trip Setting	Proof Test
PIT-0520A	Yokogawa Pressure Transmitter		EX200A-03207N (002A, K0020N19/T0003)	0-150 BarG	115 BarG	YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Input Interface						
SPD-BAI-01	MTL Surge Protector	SC332K		N/A	N/A	YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
BAI-01	P+F AI Isolator	KFD2-STCA-EX1		N/A	N/A	YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Logic Solver Input						
PAWH-0520A	SLS Module		Rack Slot, Channel			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
	AI 517-B1		Q202.01-02	4-20mA		

Sensor Element						
Sensor	Make / Device	Serial Number	Type	Range	Trip Setting	Proof Test
PIT-0520B	Yokogawa Pressure Transmitter		EX200A-03207N (002A, K0020N19/T0003)	0-150 BarG	115 BarG	YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Input Interface						
SPD-BAI-02	MTL Surge Protector	SC332K		N/A	N/A	YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
BAI-02	P+F AI Isolator	KFD2-STCA-EX1		N/A	N/A	YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Logic Solver Input						
PAWH-0520B	SLS Module		Node, Slot, Channel			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
	AI 517-B1		Q203.01-02	4-20mA		

Sensor Element						
Sensor	Make / Device	Serial Number	Type	Range	Trip Setting	Proof Test
PIT-0520C	Yokogawa Pressure Transmitter		EX200A-03207N (002A, K0020N19/T0003)	0-150 BarG	115 BarG	YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Input Interface						
SPD-BAI-03	MTL Surge Protector	SC332K		N/A	N/A	YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
BAI-03	P+F AI Isolator	KFD2-STCA-EX1		N/A	N/A	YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Logic Solver Input						
PAWH-0520C	SLS Module		Node, Slot, Channel			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
	AI 517-B1		Q204.01-02	4-20mA		

Logic Solver						
Logic solver modules	SLS module	Serial Number	Node, Slot, Channel			Proof Test
Transmitter trip	PIA-552-03		Q214.01-02/03			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
2vcc3 logic	PIA-557-03		Q216.01-02/03			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
2vcc3 logic	PIA-556-03		Q217.01			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Reset Function	PIA-557-03		Q216.04			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>

Final Element Interface						
Logic Solver Output	SLS Module	Serial Number	Node, Slot, Channel			Proof Test
SOV-CG810A	FO-526-02		Q221.02			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Output Interface						
BD0-01	P+F DO Isolator		KFD2-RCH-Ex1			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
SPD-BDO-01	MTL Surge Protector	SC332K				YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
SOV-810A	ACSO Solenoid Valve	8316A				YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>

Final Element Interface						
Logic Solver Output	SLS Module	Serial Number	Node, Slot, Channel			Proof Test
SOV-CG810B	FO-526-02		Q221.02			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Output Interface						
BD0-02	P+F DO Isolator		KFD2-RCH-Ex1			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
SPD-BDO-02	MTL Surge Protector	SC332K				YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
SOV-810B	ACSO Solenoid Valve	8316A				YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>

Final Element						
Actuator / Valve	Make	Serial number	Type			Proof Test
Actuator	BFPI		ALGAS 145-5400-725-CL			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>
CG-810	PCT	1036378	DB 16"V16" ANSI 900 RP/RP			YES <input type="checkbox"/> NO <input type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/>

Plant ID : Unit : HPPS

SIF Function : To prevent High pressure transfer to shore

Test Date and Time : Tag Number : PIT-0520A/B/C - CG-810

SIF Trip values and SIF timing

Sensor: PIT-0520A

Trip values

P&ID trip value

Field value

Logic Solver value

Remarks

Maintenance Override:

Successful YES ☐ NO ☐ N/A ☐

SIF Trip values and SIF timing

Sensor: PIT-0520B

Trip values

P&ID trip value

Field value

Logic Solver value

Remarks

Maintenance Override:

Successful YES ☐ NO ☐ N/A ☐

SIF Trip values and SIF timing

Sensor: PIT-0520C

Trip values

P&ID trip value

Field value

Logic Solver value

Remarks

Maintenance Override:

Successful YES ☐ NO ☐ N/A ☐

SIF Trip values and SIF timing

Final element: SOV-810A

Proof test times

Remarks

Additional Comments:

Final element response

SIF response time

P&ID process val. time

Time difference

SIF Trip values and SIF timing

Final element: SOV-810B

Proof test times

Remarks

Additional Comments:

Final element response

SIF response time

P&ID process val. time

Time difference

☐ FAIL ☐

☐ N.A. ☐ Date: \_\_\_\_\_

## 2. II. Creation of Proof Test Dossier: Appendix Proof test Check Sheet

### Appendix: Proof test Check Sheet

#### SIF Hardware components Sensor configuration

SIF hardware description (make, type, voting, channel, position etc.)							
Sensor Element							
Sensor	Device	Make	Type	Range	Trip Setting	Proof Test	Result
PIT-0520A	PRESSURE TX	YOKOGAWA	EJX 530A			YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Input Interface	Device	Make	Type				
SPD-BAI-01	SURGE PROTECTOR	MTL	SD32X	N/A	N/A	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
BAI-01	AI BARRIER	P&F	KFD2-STC4-EX1	N/A	N/A	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Logic Solver Input	SLS Module	Make	Rack, Slot, Channel				
PAHH-0520A	AI-517-B1	YOKOGAWA	TBA			YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>

SIF hardware description (make, type, voting, channel, position etc.)							
Sensor Element							
Sensor	Device	Serial Number PT	Type	Range	Trip Setting	Proof Test	Result
27-PT-1501A	EJX530A		GAUGE	0-110 bar	102 barg	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Input Interface	Device	Make	Type				
N/A	N/A	N/A	N/A			YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Logic Solver Input	RS Module	Serial Number RS	Node, Slot, Channel				
27-PT-1501A	SAI143-H53		N01S01C01		Tag name - _27PT1501A	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>

## 2. II. Creation of Proof Test Dossier: Appendix Proof test Check Sheet

### Appendix: Proof test Check Sheet

SIF Hardware components logic solver

#### Programmable Logic Solver (PE)

Logic Solver						
Controller	RS module	Serial Number RS	Node, Slot	Proof Test		Result
SCS0101	S2CP471-01	/	N01S09, N01S10	YES <input type="checkbox"/>	NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>

#### Solid state Logic Solver ( E )

Logic Solver								
Logic solver modules	SLS module	Serial Number	Node, Slot, Channel			Proof Test		Result
Transmitter trip	FM-552-03		0214.01/02/03			YES <input type="checkbox"/>	NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
2oo3 logic	FM-557-00		0216.01/02/03			YES <input type="checkbox"/>	NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
2oo3 logic	FM-556-00		0217.01			YES <input type="checkbox"/>	NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Reset Function	FM-557-00		0216.04			YES <input type="checkbox"/>	NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>

## 2. II. Creation of Proof Test Dossier: Appendix Proof test Check Sheet

### Appendix: Proof test Check Sheet

#### SIF Hardware components Final Element Configuration

Final Element					
Logic Solver Output	RS Module	Serial Number RS	Node, Slot, Channel	Proof Test	Result
_27HY080A	SDV531-L53		N01S03C01	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
_27HY080B	SDV531-L53		N01S03C02	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Output Interface	Device	Make	Type		
27-EV-080	Solenoid Valve	BIFOLD	FP05	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
27-EV-080	Actuator	Servo valve	RSOM 6000/160S	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Valve	Device	Serial Number	Type		
27-EV-080	Ball Valve		T3 Type 18"	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Logic Solver Output	RS Module	Serial Number RS	Node, Slot, Channel	Proof Test	Result
_27HY081A	SDV531-L53		N01S03C04	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
_27HY081B	SDV531-L53		N01S03C05	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Output Interface	Device	Make	Type		
27-EV-081	Solenoid valve	BIFOLD	FP05	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
27-EV-081	Actuator	Servo valve	RSOM 6000/160S	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Valve	Device	Serial Number	Type		
27-EV-081	Ball Valve		T3 Type 18"	YES <input type="checkbox"/> NO <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>

## 2. II. Creation of Proof Test Dossier: Appendix Proof test Check Sheet

### SIF Trip Values and SIF response time Timing


SIF Trip values and SIF timing				
Sensor : PIT-0520C				
Trip values	P&ID trip value	Field value	Logic Solver value	Remarks
"0"				
Maintenance Override:				
Successful: YES <input type="checkbox"/> NO <input type="checkbox"/> N/A <input type="checkbox"/>				
SIF Trip values and SIF timing				
Final element: SOV-810A			Additional Comments:	
Proof test times	(hh:mm:ss)	Remarks		
Sensor trip at time				
Final element response				
SIF response time				
P&ID process saf. time				
Time difference				

## 2. III. Proof Test: Execution at Site

### What proof test scope is possible?

Proof testing of  
PT101-10 & PT101-2

HOW?



- Only a block valve (no bleed).

Proof test options:

- Remove Transmitter to test wetted part  
Or
- No disconnection .... Use HART Communicator

What about the Note:

14. SETTINGS TO BE CONFIRMED BASED ON BURNER TEST.

## 2. III. Proof Test: Execution at Site

### What proof test scope is possible?

### Proof testing of PT-979A/B/C

#### How?


- Manifold Block / Bleed valve

#### Proof test options:

- Calibrated Pressure source  
Or
- No pressure source available - HART Communicator

#### What about Proof Test possibilities for

- in-line Flow transmitters,
- Level Switches/transmitters,
- Temperature transmitters




## 2. III. Proof Test: Execution at Site; Proof Test limitations

### Testing the sensors and final elements was done in different ways:

- Via simulation (HART) the Sensor output side (only HART PTC can be claimed)
- Via simulation on the sensor input side (maximum PTC can be claimed)
- Via Jumpers on the sensor output (at device terminals) side (PTC claim??)
- Via Calibration field equipment (e.g. for TT) and the HART simulation in the field (maximum PTC can be claimed)
- The simulations on the sensor input side are mainly done by using HART, instead of actual field simulation, as requested by client.
- Final elements partly included due to the parallel valve overhaul activities/Time constrain. Resulted in limited valve testing (PTC claim??)
- Proof Test Scope to be recorded as part of the auditable trail: Against what design basis the SIF was tested (e.g. filled in procedures, revision, and completeness) is recorded, incl. limitations

## Recording of the results

- Application logic Printscreen.



## 2. III. Proof Test: Execution at Site

### Recording of the results

- Application Logic Print screen.
- BPCS HMI Graphics / Face Plates.
- Complete check sheet records with field equipment data.

#### **In addition, other records collected (when available)**

- Sequence of Event Recorder @ SIS and / or BPCS
- Alarm Management system (Hardwired based / Software based)
- Other systems (e.g. PI-server)


*and*

- Maybe pictures (Dated):      Visual inspection  
   Proof of activation.

## 2. IV. Proof Test results: Independent Stage 4 FS Assessment

### What is done:


- Verify all SIF's which are proof tested.
- Any assessment limitations and the safety impact analysed.
- Verify Proof test coverage – affects PFDavg calculation and next proof test interval
- Verify Document basis for Proof test
- Proof Test Engineering process with the Verification/Validation checks
- Actual equipment installed and failure data used.
  - Sensors, 3<sup>rd</sup> party interfaces, Logic Solver Final element Configuration.



## 2. IV. Proof Test results: Independent Stage 4 FS Assessment

### What is done:


- Actual proof test records verification
  - General assessment and assessment by area
  - Proof test results
- Completed the FSM for Operation and Maintenance Phase checklist; How good/bad is client FSM
- Final Assessment of this proof test project –  
**199 open items for the SIF's - mainly Systematic issues and many SIF's did not meet SIL 3 (Mostly Financial SIL)**
- SIF Re- Calculation based on actual PTC;  
Still meets SIL or Recommend new proof test period to meet SIL.



### 3. Results of recent Proof Test Execution

-

#### Independent Stage 4 FS Assessment



## Project 2: Proof Test deficiencies for improvement

1. Provide Safety Requirement Specification based on a Hazard and Risk Analysis. See IEC61511 Ed 2, Part 1 chapter 10.3 for SRS requirements.
2. Include basis of design and other operational documents as part of the Proof Test results to verify if the assumptions done with respect to expected demand/Failure rate of the system and documentation are still matching. E.g. (false) trip evidence over the past period.
3. Specify and Inspect the installed hardware components against the components of the original specification.
4. Specify the proof test intervals and process safety times on which the  $PFD_{avg}$  calculations are based.
5. Compare the current proof test results with the latest proof test results to detect behavioral changes and/or trends.

## Project 2: Proof Test deficiencies for improvement

6. Consider process trips as proof tests and document them accordingly. These to be noted with the proof test results for comparison purposes.

7. Overall Loop response time of 2.7 and 2 seconds, respectively.

Valves closing times are recorded and show closing within this response time, but the transmitter and logic solver response time has not been recorded.

As such no conclusion can be made if the overall Loop Response Time meet the Process Safety time for the 5 HIPPS system (Trains).

8. Proof test shows that the valves closed on the high trip but no conclusion can be made that all undetected faults that prevent the HIPPS from operating in accordance with the SRS are fulfilled. Valve proof test requirements are not available.

Specify a detailed proof test to meet the IEC61511 Ed 2, Part 1 chapter 16.3.1 requirements

# Project 3: FSM Deficiencies in Proof Test Report

Item	Issue	IEC61511 Ed. 2 Pt.1 Clause
1	The document front sheet with names of author, reviewers, approvers, revision etc. is missing. There is no review, approval and control scheme applied. Table of Contents does not match the report order, format and pages.	19.2.6 / 7 / 8
2	Report indicates no information on achieving and maintaining functional safety of the SIS.	19.2.9
3	The Recommendation for improvements & observations are referred to appendices but no information is provided. Therefore, it is unclear what is the conclusion	16.3.2 / 16.3.1.3 / 16.3.1.6
4	Some “major” observations are not supported/elaborated by the report. As such there there is no design/operational basis for these observations	16.3.2 / 19.2.9
5	There is no analysis to justify the claim that the installed equipment are still within the useful lifetime.	16.3.1.6 16.3.2
6	No information provided on the SRS and Design documents.	19.2 / 16.3.1.6

# Project 3: FSM Deficiencies in Proof Test Report

Item	Issue	IEC61511 Ed. 2 Pt.1 Clause
9	Prerequisite for proof test has not been defined.	16.3.1.1. / 19.2
8	The used (Calibrated) test equipment for Proof Test is not recorded.	16.2.2
9	No information on end-user responsibility for proof testing.	16.3.1.1/ 16.3.1.5
10	No schedule information on proof test.	16.3.1.3
11	Punch list form incl impact Analysis is not available.	16.3.1.4 / 16.3.1.6
12	No project information is available on the HIPPS itself.	16.3.3 / 19.2.29
13	Signature missing of the recorded and involved (customer) persons.	16.3.3
14	System drawings not available at site.	16.3.3 / 19.2.9
15	Visual inspection not based on any drawings and lacking references. Items cannot be confirmed as done. Actual measuring points are unclear and not documented. No measurements provided as proof that it is ok.	16.3.3
16	Visual inspection of field equipment is not recorded.	16.3.2

# Project 3: FSM Deficiencies in Proof Test Report

Item	Issue	IEC61511 Ed. 2 Pt.1 Clause
17	Unclear how application logic is checked. Not covered in the proof test procedure.	16.3.1.1/ 16.3.3
18	Chapter name is Annual test and set on 1 year, but the project Safety Validation Plan specifies 18 months. There is no record to show that this time interval is maintained since the last record in 2018.	16.3.1.3 / 16.3.1.5
19	<p>Proof test table: This proof test procedure is severely incomplete and lacking any test to reveal undetected faults. It is just a limited function check.</p> <p>A SIF 2oo3 Transmitters and 1oo2 Valves must be tested for every possible functionality and identify failures and possible common cause issues. Further the Proof Test Coverage is not defined.</p> <p>No Datasheet and Loop test check sheet of the installed equipment is provided.</p>	16.3.1.1 / 16.3.3 / 19.2.9
20	No punch form with impact analysis provided. Punch items overview is incomplete and not matching the punch items recorded.	16.3.1.4 / 16.3.1.6

## 4. Key Take Aways

- Proof test “Buzz word” - Easier said then done.
- Proof test is to detect dangerous undetected failures in the SIF.
- Good proof testing require a detailed planning, proper documentation, manpower, time and budget.
- Proof test during TA schedule is limited due to time constrain and many parallel activities/pressure to complete on time.
- Inspection is required as part of Proof Test

## 4. Key Take Aways

- The Proof Test Coverage can be a serious limitation – which can result in additional Proof testing to meet the SIF SIL requirement.
- FSM in the Operational Phase is mostly not established - No Systematic Capability (SC) for the Operator of the Facility
- Analyze Proof test results – limited follow up due to budget/time/ knowledge constrain
- Most of the verification process is still a manual (Human) activity. Still Limited possibilities to improve this process with digitalization.

Terimah Kasih (Thank you)

Co-innovating tomorrow™

[Arjen.de.Koning@yokogawa.com](mailto:Arjen.de.Koning@yokogawa.com)

[Safetyassessments@yokogawa.com](mailto:Safetyassessments@yokogawa.com)

