

# LEARNING FROM TANK OVERFILLING INCIDENT AT MOL GROUP

**Róbert Gyulai**

PSM expert

16.12.2025 AACHEN, EPSC



# AGENDA

- 1 INTRODUCTION
- 2 INCIDENT OVERVIEW
- 3 ANALYSIS - BOWTIE
- 4 CONCLUSION and LEARNINGS
- 5 SAFETY VIDEO



# Róbert Gyulai

## About Me

Incident Investigation and  
Risk Management Expert



### Address

MOL Plc. Danube Refinery  
Hungary



### Contact Numbers

+36/20-914-5168



### Email:

rgyulai@mol.hu



### Slogan

May the **Safety** Be With  
You



### Workplace

MOL plc.  
DS Production  
Process Safety Management



### Education

Chemical engineer  
Corrosion Protection Engineer  
Internal auditor




### Work experience

25 years experience  
• 10 years in Operation  
• 15 years in Process  
Safety Management

# INCIDENT OVERVIEW

## WHAT HAPPENED



1. At 03:00 on 22.12.2024, the tank (T2022) was overfilled and the DGHT1 product was leaking out of the side breather on the tank shell.
2. After overfilling was detected, tank filling was stopped.
3. Unfortunately, the dike drain valve was open, allowing the material to escape from the tank through the non-process sewer system to the wastewater treatment unit.

TIER classification: **TIER1**


# BOWTIE FOR INCIDENT VISUALIZATION

- MAP OUT THE FULL PICTURE OF AN INCIDENT
- CLEAR COMMUNICATION: SHOWS HOW THE INCIDENT HAPPENED OR COULD HAPPEN
- ROOT CAUSE ANALYSIS: HELPS IDENTIFY WHICH BARRIERS FAILED OR WERE MISSING.
- RISK AWARENESS: HIGHLIGHTS WEAK POINTS IN THE SAFETY SYSTEM.


## TREAT & PREVENTIVE BARRIERS

## ROOT CAUSES


## TOP EVENT & CONSEQUENCES



# HAZARD, TOP EVENT AND CONSEQUENCES



# THREATS & PREVENTIVE BARRIERS




# ROOT CAUSES

## **Human factor -**

Due to increased alarm signals during the upset in the unit, the operator did not prioritise the high level signal properly

## **Root cause -**

Workload issue, inattention to details - Tank filling has not been stopped after a high level signal by operator - PSF7




# ROOT CAUSES

## **Design –**

The DCS did not provide proper information for transfer of material between tanks and units

## **Root cause –**

The design philosophy was inappropriate - The DCS does not directly read the data of the tanks belonging to the controlled systems




# ROOT CAUSES

## Communication – Information

It is not clear and difficult to keep track of which measurement/sensor belongs to which tank and where it appears

## Root cause -

Content issue - Information was not provided, was wrong, not clear or wrongly interpreted - Not proper visualization of key parameters/ tank levels on DCS




# ROOT CAUSES

## **Risk assessment –**

The change of the DCS interface was not preceded by a MOC process and was not followed up with information (training)

## **Root cause -**

Risk assessment for given task/activity not performed - No risk assessment of the consequences of changing the DCS interface for the relevant units




# ROOT CAUSES

## Rules, Regulations, Documentation –

The process was controlled by PI Vision with not up to date level data - There are a differences between the verification report ,D-Plan and NICE device management database data

## Root cause -

Regulation, documentation incorrect or incomplete, not up-to-date - Maximum level height and overflow height are included in the protocol (reports) but the current maximum filling height is not




# ROOT CAUSES

## **Ineffective communication structure –**


There was no proper communication between units

## **Root cause -**


Ineffective communication structure (not clear who should receive or request what information, whom to notify, etc.) - No information provided about reached the high-level alarm and maximum level height



# PROCESS SAFETY FUNDAMENTALS




1. Proper equipment isolation




6. Verify the condition of flexible hoses




2. Safe Opening of Equipment



7. Operate within safe limits




3. Monitor an open drain




8. Identify Safety Critical Equipment (SCE)



4. Manage overrides of safety critical systems



9. Ensure safe atmosphere in fire box before igniting the burners





5. Walk the Line




10. Do not make a change without a proper MoC process

# FINDINGS – PROCESS SAFETY FUNDAMENTAL RELEVANCE



**PSF7**

Operate within safe limits



**PSF5**

Walk the line



**PSF10**

Do not make a change without  
a proper MoC process

The filling of the tank has not been stopped after the high-level alarm - **Don't ignore the alarm signals, as they warn you of danger!**

The dike's drain valve was open and this was not checked by the tank owner or the loading unit that initiated the tank filling  
**Always verify all material flow paths before starting any operation**

The change of the DCS interface was not preceded by a MoC process and was not followed up with information (training)  
**Share the relevant information with all concerned!**

# SAFETY VIDEO CONCEPT



01

It is essential not only to **establish** Process Safety Fundamentals but also to **communicate them effectively** and ensure they reach every employee

We want the application of process safety rules to become a natural part of our daily work, and for every employee **to pay attention** to them instinctively. To support this, **we have created an educational video** series that presents these fundamentals in a playful, easy-to-digest format, **helping colleagues learn** and stay aware of process safety rules



02



**MAY THE  
SAFETY BE  
WITH YOU...**